

Amy Ow

From: Camille Leung
Sent: Tuesday, November 26, 2019 11:27 AM
To: Robert Pellegrine
Cc: Kristen Outten; Jessica Henderson-McBean; Amy Ow; Steve Monowitz; Noel Chamberlain
Subject: RE: Site Visit 11/25/19 - Silt Fence Requirement

Hi Bob,

Please address all the corrections.

If the site is going to be shuttered for winter, SWCA will be checking that all long-term erosion control measures are in place to last the rest of the winter. They will conduct weekly inspections until they can confirm the site is completely and adequately stabilized. After that, they will be inspecting on a monthly basis to see how measures are holding up. Please coordinate with them on these inspections as you will need to be there to receive and implement any corrections in a timely manner.

Thanks

From: Jessica Henderson-McBean [mailto:JHenderson-McBean@swca.com]
Sent: Monday, November 25, 2019 6:07 PM
To: Robert Pellegrine <robertpellegrine@yahoo.com>
Cc: Camille Leung <cleung@smcgov.org>; Kristen Outten <koutten@swca.com>
Subject: RE: Site Visit 11/25/19 - Silt Fence Requirement

CAUTION: This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

Bob,

Thank you for addressing our action items. I will look for your photos with completed silt fence repairs, tomorrow.

Have a great evening.

Jessie Henderson-McBean
Biologist

SWCA Environmental Consultants
60 Stone Pine Road, Suite 100
Half Moon Bay, CA 94019
P 650.440.4160 x 6410 | C 805.712.8794



The contents of this email and any associated emails, information, and attachments are CONFIDENTIAL. Use or disclosure without sender's authorization is prohibited. If you are not an authorized recipient, please notify the sender and then immediately delete the email and any attachments.

From: Robert Pellegrine <robertpellegrine@yahoo.com>
Sent: Monday, November 25, 2019 6:04 PM
To: Jessica Henderson-McBean <JHenderson-McBean@swca.com>
Subject: Re: Site Visit 11/25/19 - Silt Fence Requirement

EXTERNAL: This email originated from outside SWCA. Please use caution when replying.

Good evening
I will send photos of the silt fence with completed repairs
The SWIPP doc is ready for me to pick up by 10am Tues
from Belmont (a short drive)
United sanitation is installing the drip pan Tues also
We are preparing job to shutter also Tues until spring
Thanks
Bob Pellegrine Superintendent
Nexgen Builders

Sent from my iPhone

On Nov 25, 2019, at 5:22 PM, Jessica Henderson-McBean <JHenderson-McBean@swca.com> wrote:

Hello Bob,

Thank you for your voicemail earlier today, I did get your message that you placed some dirt around the base of the silt fence. Can you please provide photos of the repairs you have made, so that we can confirm that silt fence has been fixed?

Attached you will find a copy of the site inspection report from today. Please note that silt fence should be installed per the requirements of CASQA (see attached guidance entitled "se-1") and the project SWPPP.

As a summary of what we discussed onsite today, please address the following action items:

1. Complete repairs of the silt fence, and key in the entire bottom. Please complete this repair by **Wednesday (11/27/19)** in preparation for the upcoming rain event. Please send me photos of the completed repairs so that we can confirm that the silt fence has been properly installed.
2. Please obtain a copy of the project SWPPP to be kept on the site, and retain a QSD/QSP to begin SWPPP inspections as per the SWPPP requirements.
3. Please install a secondary containment drip pan beneath the port-o-john onsite.

My next inspection is scheduled for Monday 12/2/2019. Please note, if the silt fence repairs have not been made by Monday 12/2/2019, the County may invoke a stop work order.

Thanks so much,

Jessie Henderson-McBean
Biologist

SWCA Environmental Consultants
60 Stone Pine Road, Suite 100
Half Moon Bay, CA 94019
P 650.440.4160 x 6410 | C 805.712.8794

<image001.png>

Visit Our New [Website!](#)

The contents of this email and any associated emails, information, and attachments are CONFIDENTIAL. Use or disclosure without sender's authorization is prohibited. If you are not an authorized recipient, please notify the sender and then immediately delete the email and any attachments.

<Inspection_Report_Form_11.25.19.pdf>

<se-1.pdf>